

FOURTEENTH QUARTERLY REPORT
(PERIOD: JULY 1, 2019 TO SEPTEMBER 30, 2019)

PARTIAL CONSENT DECREE CASE NO. 4:16-CV-00018
CITY OF GREENVILLE, MS

SUBMITTED TO:

U.S. Environmental Protection Agency, Region 4
Clean Water Enforcement Branch
61 Forsythe Street, S.W.
Atlanta, GA 30303-8960




November 8, 2019

CERTIFICATION

14th Quarterly Report
Partial Consent Decree
City of Greenville

I certify under penalty of law that this document and all its attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.



Errick D. Simmons, Mayor

11-8-19

Date

FOURTEENTH QUARTERLY REPORT
 OCTOBER 28, 2019
 PARTIAL CONSENT DECREE
 U.S. DISTRICT COURT CIVIL ACTION 4:16-cv-00018

Work Order #	Work Date	Main Status	WO Asset	Requester Name	Request Type	Address	Phone Number	Email	Event Name	Location	Customer Description	Work Type	Work Description	Date Delivered	Received By	Department	Assigned To	Longitude	Latitude	Map Address	SSD	Duration (hours) If SSD	Volume (gallons) If SSD	Waters Of U.S.	Cause	Group	Mini-system	Pump Station
55411	7/16/2019 9:58	Closed	0	Nathaniel Watkins	0	1013 N. Broadway	931-3572		0	0	Sewer standing in front yard, c/o?	0	problem on p/o unblocked // VG	7/16/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	2	3
56107	8/22/2019 7:58	Closed	0	washington	0	730 Simpson Rd			0	0	s/bu, c/o front	0		8/16/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	2	3
55062	7/1/2019	Open	0	LEE PHINISE	0	711 Phelps Street	870-814-3997		0	0	turn the pump on please- s/bu on K. D.	0	tuned pump	7/1/2019		670 Sewer	Jeff Appleton	33.395551	-91.06753	0	No					1	7	16
55065	7/1/2019 9:51	Closed	0	Knight	0	1516 Delesseps	662-347-8922		0	0	sewer issue after line was flushed out across the street.	0		7/1/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	8	17
55304	7/1/2019	Open	0	Ruffin Ruffin	0	1816 Dahlva Avenue			0	0	Customer is asking to speak with the Division Chief.	0				670 Sewer	Jeff Appleton	0	0	0	No					1	8	17
55454	7/17/2019 13:23	Closed	0	Greene	0	1407 Roosevelt Street	662-931-0491		0	0	sewage water coming up out the drain, running into drain, now drains are full	0	P/O c/o is down // VG	7/18/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	8	17
55458	7/18/2019 8:29	Closed	0	Lee	0	1424 Booker Street	336-3448		0	0	sewer problem, c/o?	0	water standing between houses, no c/o present // VG	7/17/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	8	17
55954	8/9/2019 13:42	Closed	0	family of 4	0	1325 Highway 82 West			0	0	need tap for family dollar store	0	install 4" sewer tap R.King	8/9/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	8	17
55978	8/15/2019 9:30	Closed	0	Cornelius Buck	0	1503 S. Delesseps	601-519-7253		0	0	s/bu, c/o front	0	unblocked // VG	8/12/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	8	17
55120	7/3/2019 8:12	Open	0	sol Masia	0	303 Giddens Street	662-347-6928		0	0	s/bu- stopped up - plumber has been there 3 times- DEFINE THE PROBLEM	0				670 Sewer	Jeff Appleton	0	0	0	No					1	10	38
55178	7/8/2019 11:13	Open	0	SHRILEY PACE	0	104 PAULINE PLACE	662-931-5655		0	0	HAS TWO SINK WHOLES IN THE BACK YARD AROUND THE BIG DRAIN	0				670 Sewer	Jeff Appleton	33.380226	-91.05445	0	No					1	10	38
55608	7/25/2019 7:12	Closed	0	resident n/a	0	104 Pauline Street			0	0	sink hole in rear	0	replace 4" sewer service line R.King	7/24/2019		670 Sewer	Fredrick Johnson	0	0	0	No					1	10	38
55809	8/2/2019 12:59	Closed	0	Sandra Hamilton	0	204 St. Anthony	931-1820		0	0	s/bu, c/o front	0	Unblocked // VG	8/2/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	10	38
55923	8/8/2019	Closed	0	Sandy Hamilton	0	204 Saint Anthony Street	662-931-1820		0	0	sewer issue - toilets will not flush	0	unblocked // VG	8/12/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	10	38
55447	7/17/2019	Closed	0	customer customer	0	525 North Delta Street			0	0	customer said sewage is backing up in her house and in the yard	0	City side down // VG	7/25/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	18	28
55877	8/7/2019 7:06	Closed	0	washington	0	539 7th St			0	0	sewer bagging out clean out in the front	0	Unblocked // VG	8/6/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	18	28
56468	9/11/2019 7:56	Closed	0	Marie Stall	0	549 Abraham St	332-0999		0	0	Sewer issue- requests main line blow-out at Hospital St.	0	clean // VG	9/6/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	18	28
56712	9/18/2019	Open	0	Leslie Wise	0	225 Garrett	662-822-1291		0	0	sewage backing up and running into the flower bed.	0	sewer issue			670 Sewer	Jeff Appleton	0	0	0	Yes	unknown	unknown			1	18	28
56770	9/20/2019	Open	0	Citizen	0	206 S Sixth	662-233184		0	0	s/bu, pipes exposed where we tore down vacant house	0				670 Sewer	Jeff Appleton	0	0	0	No					1	18	28
55369	7/15/2019	Closed	0	Pat Williams	0	2446 North Sanillo Circle			0	0	sewer back up	0	Lift station problem // VG	7/18/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	20	27
55476	7/18/2019	Closed	0	CUSTOMER	0	607 Canley			0	0	sewer backing up	0	problem corrected	7/24/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	20	28
55706	7/29/2019	Closed	0	J. Z. Jones	0	611 East McConkle Circle			0	0	sewer issue- back-up	0	City side down, problem on PRO // VG	8/1/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	20	28
55946	8/9/2019 9:38	Closed	0	contractor	0	John DeLa Bus Terminal	335-2144		0	0	Sewer main surcharged along old K-Mart parking area.	0	unblocked // VG	8/9/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	20	28
56222	8/22/2019 9:46	Closed	0	customer customer	0	3107 Hwy 82 E			0	0	s/bu, c/o rear	0	got it down // VG	8/22/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	20	28
56592	9/13/2019	Open	0	customer customer	0	627 West McConkle Circle			0	0	sewage backing up	0				670 Sewer	Jeff Appleton	0	0	0	No					1	20	28
56823	9/24/2019	Closed	0	Brenda Hall	0	627 W. McConkle Cir.	662-347-8479		0	0	S/B/U	0				670 Sewer	Jeff Appleton	0	0	0	No					1	20	28
55146	7/3/2019 10:53	Open	0	Tracy Wilson	0	252 Wildwood Drive	820-3327		0	0	City have a noisy bypass pump out there it has been out there over a month. It's a puddle of water in front of her house and the water smell is unbearable. Need you to call her, Jermaine.	0				670 Sewer	Jeff Appleton	0	0	0	No					1	27	41
55711	7/29/2019 15:13	Open	0	resident n/a	0	466 Risewild Drive			0	0	sink hole in front yard by street	0	Fixed pumps // VG			670 Sewer	Jeff Appleton	0	0	0	No					1	27	42
55989	8/12/2019	Closed	0	Berzing	0	Wildwood Drive	217-474-8021		0	0	sewage flowing the street again	0				670 Sewer	Jeff Appleton	0	0	0	Yes	unknown	unknown			1	27	53
56227	8/22/2019	Closed	0	customer customer	0	Wildwood Road			0	0	customer said the sewer pump has stopped running. been idle for 3 hours. Only one call from this area.	0	pumps are running // VG	8/23/2019		670 Sewer	Jeff Appleton	0	0	0	No					1	27	53

FOURTEENTH QUARTERLY REPORT
 OCTOBER 28, 2019
 PARTIAL CONSENT DECREE
 U.S. DISTRICT COURT CIVIL ACTION 4:16-cv-00018

Work Order #	Work Date	Main Status	WO Asset	Requester Name	Request Type	Address	Phone Number	Email	Event Name	Location	Customer Description	Work Type	Work Description	Date Delivered	Received By	Department	Assigned To	Longitude	Latitude	Map Address	SSO	Duration (hours) if SSO	Volume (gallons) if SSO	Waters of U.S.	Cause	Group	Mini-system	Pump Station
56518	9/9/2019 14:59	Closed	0 R.Washington	0 R.Washington	0 1807 Lames Cove	0	0	0	0	0	0	0	0	9/9/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No			1	27	71	
56806	9/23/2019	Closed	0 Hubbard Stephens Cypresswood Apartments	0 Hubbard Stephens Cypresswood Apartments	0 616 Wildwood Dr.	6625880185	0	0	0	0	0	0	0	0	Lauren Gales	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	1	27	71
56803	9/23/2019	Closed	0 Ktespie	0 Ktespie	0 564 Cypress Ln	662357333	0	0	0	0	0	0	0	0	Lauren Gales	670 Sewer	Jeff Appleton	0	0	0	0	No			1	27	71	
55165	7/8/2019 9:40	Closed	0 Ktespie	0 Ktespie	0 3004 East Alexander Street	3478424	0	0	0	0	0	0	0	7/15/2019	Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			1	30	24	
55903	8/7/2019 14:12	Closed	0 MARTIN	0 MARTIN	0 275 Stockton Drive	662-931-0301	0	0	0	0	0	0	0	8/12/2019	Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			1	30	56	
56257	8/26/2019	Closed	0 Hattie Davis	0 Hattie Davis	0 2529 Saint James	662-335-5851	0	0	0	0	0	0	0	9/5/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No			1	30	56	
56303	8/27/2019 13:41	Closed	0 L.T. Bryant	0 L.T. Bryant	0 260 S. Beauchamp	0	0	0	0	0	0	0	0	8/27/2019	Adley	670 Sewer	Jeff Appleton	0	0	0	0	No			1	30	56	
56355	8/29/2019 9:55	Closed	0 Glen Davis	0 Glen Davis	0 Alexander & Beauchamp	9315355	0	0	0	0	0	0	0	9/5/2019	Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			1	30	56	
56363	8/29/2019 13:34	Closed	0 pastor williams	0 pastor williams	0 250 Behaven Street	0	0	0	0	0	0	0	0	8/29/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	1	30	56
56198	9/5/2019 9:44	Closed	0 F.washington	0 F.washington	0 Behaven & Alexander	0	0	0	0	0	0	0	0	8/21/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No			1	30	56	
56161	9/5/2019 9:48	Closed	0 citizen	0 citizen	0 N. Cornell Ave	334-4072-2387	0	0	0	0	0	0	0	8/20/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No			1	30	56	
56680	9/18/2019	Open	0 Linda Carter	0 Linda Carter	0 245 N. Beauchamp	0	0	0	0	0	0	0	0	0	M. Kearney	670 Sewer	Jeff Appleton	0	0	0	0	No			1	30	56	
55699	7/25/2019 7:26	Closed	0 resident n/a	0 resident n/a	0 1108 East Gamwyn Drive	0	0	0	0	0	0	0	0	7/24/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No			1	95	39	
55164	7/8/2019 9:30	Open	0 Johnson	0 Johnson	0 273 Clover Cir	662-347-0402	0	0	0	0	0	0	0	0	Winters	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	1	12A	56
55528	7/22/2019 9:53	Closed	0 Byron Cantledge	0 Byron Cantledge	0 273 Clover Cir	662-347-4035	0	0	0	0	0	0	0	7/24/2019	Bridget Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			1	12A	56	
55565	7/23/2019	Closed	0 LeKeisha Johnson	0 LeKeisha Johnson	0 273 Clover Cir	0	0	0	0	0	0	0	0	7/25/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No			1	12A	56	
55800	8/2/2019 8:48	Closed	0 R. Washington	0 R. Washington	0 164 Burnside Dr.	0	0	0	0	0	0	0	0	8/2/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No			1	12A	56	
56919	9/30/2019 7:56	Closed	0 KFC-SHAMEKIA	0 KFC-SHAMEKIA	0 1923 Highway 82 E	662826496	0	0	0	0	0	0	0	1/1/1900	Bridget Winters	670 Sewer	Jeff Appleton	33.399883	-91.02797	0	0	No			1	19A	28	
55554	7/23/2019 8:58	Closed	0 Linda Perkins	0 Linda Perkins	0 2002 Tucker Street	825-7913	0	0	0	0	0	0	0	7/25/2019	Winters	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	1	19B	28
55977	8/12/2019 11:18	Closed	0 #31	0 #31	0 1949 East Alexander Street	0	0	0	0	0	0	0	0	8/12/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No			1	19B	28	
55999	8/13/2019 9:48	Closed	0 Morey	0 Morey	0 1915 Lebanon Lane	662-822-6603	0	0	0	0	0	0	0	8/14/2019	Bridget Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			1	19B	28	
56102	8/16/2019 9:45	Closed	0 Sheva White	0 Sheva White	0 1949 East Alexander Street	0	0	0	0	0	0	0	0	0	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No			1	19B	28	
56659	9/17/2019	Open	0 Mack Anthur	0 Mack Anthur	0 525 North Delta	662-822-1069	0	0	0	0	0	0	0	0	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No			1	19B	28	
56844	9/24/2019	Open	0 citizen	0 citizen	0 315 California	662-822-3871	0	0	0	0	0	0	0	0	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No			1	19B	28	
55570	7/25/2019 8:23	Closed	0 citizen	0 citizen	0 1204 Washaw Dr.	0	0	0	0	0	0	0	0	7/23/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No			1	21A	29	
55618	7/25/2019	Closed	0 Samuel Brothers	0 Samuel Brothers	0 Platt Road	0	0	0	0	0	0	0	0	7/29/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No			1	31B	23	

FOURTEENTH QUARTERLY REPORT
 OCTOBER 28, 2019
 PARTIAL CONSENT DECREE
 U.S. DISTRICT COURT CIVIL ACTION 4:16-cv-00018

Work Order #	Work Date	Main Status	WO Asset	Requester Name	Request Type	Address	Phone Number	Email	Event Name	Location	Customer Description	Work Type	Work Description	Date Delivered	Received By	Department	Assigned To	Longitude	Latitude	Map Address	SSO	Duration (hours) if SSO	Volume (gallons) if SSO	Waters of U.S.	Cause	Group	Mini-system	Pump Station		
55822	8/5/2019 9:25	Closed	0 William Manor	0 William Manor	0 2580 Old Leland Rd.	822-5579 (Rumal)	0	0	0	0	0 Water spill like terrible	0	Checked chlorine, flushed main line, no odor in area. // RR	8/5/2019	Felicia Wilkerson	670 Sewer	Milton Kearney	0	0	0	No	0				1	31B	23		
56155	8/20/2019 11:25	Open	0 Candice Thornton	0 Candice Thornton	0 466 N Cornell Apt. 37B	344-3273	0	0	0	0	0 Sewer discharge from apt. at driveway	0	0 Sewer discharge from apt. at driveway	8/20/2019	Jeff Appleton	0 670 Sewer	Jeff Appleton	0	0	0	No	0				1	31B	94		
55332	7/12/2019 8:44	Closed	0 JOHN RICHARDSON	0 JOHN RICHARDSON	0 SOLOMON & OLD LELAND RD	0	0	0	0	0	0 SINK HOLE IS OPENING UP	0	problem resolved street dept. patch pot hole	7/23/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	No	0				1	32A	22		
55998	8/13/2019 9:56	Closed	0 San'ya Lewis	0 San'ya Lewis	0 1286 Belcrest Street	820-6766	0	0	0	0	0 Sewer problem, c/o ?	0	breakdown // unblocked //	8/13/2019	Jeff Appleton	0 670 Sewer	Jeff Appleton	0	0	0	No	0				1	32A	21		
56061	8/15/2019 7:17	Closed	0 #14	0 #14	0 1286 Belcrest St.	0	0	0	0	0	0 s/bu. looks to be on City side per #14	0	unblocked //	8/15/2019	Jeff Appleton	0 670 Sewer	Jeff Appleton	0	0	0	No	0				1	32A	21		
56105	8/22/2019 7:59	Closed	0 Robert McNeil	0 Robert McNeil	0 787 Shannon Street	743-9118	0	0	0	0	0 S/bu. c/o front	0	unblocked //	8/16/2019	Jeff Appleton	0 670 Sewer	Jeff Appleton	0	0	0	No	0				1	32A	21		
56199	8/23/2019 9:10	Closed	0 A Barnes	0 A Barnes	0 1240 Parkview Drive	336-9002	0	0	0	0	0 s/bu. c/o rear, near fence	0	Unblocked line, but might be an oncoming sewer failure.	8/21/2019	Jeff Appleton	0 670 Sewer	Jeff Appleton	0	0	0	No	0				1	32B	20		
55449	7/17/2019	Closed	0 customer customer	0 customer customer	0 526 north sheby street	0	0	0	0	0	0 owner of complex reporting remains complaining about not being able to flush their toilets in the last three days or more.	0	Unblocked //	7/18/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	No	0				1	3B	55		
55440	7/17/2019 9:13	Closed	0 Melvin Hudson	0 Melvin Hudson	0 526 N. Sheby	931-0720	0	0	0	0	0 Sewer backup, c/o rear.	0	Unblocked //	7/17/2019	Jeff Appleton	0 670 Sewer	Jeff Appleton	0	0	0	No	0				1	3B	55		
55839	8/6/2019 8:44	Closed	0 Guimnde Phillips	0 Guimnde Phillips	0 538 Culey St	702-3497	0	0	0	0	0 Sewer blockage, c/o front, plumber says on City	0	Unblocked //	8/6/2019	Jeff Appleton	0 670 Sewer	Jeff Appleton	0	0	0	No	0				1	3B	55		
56560	9/11/2019 13:45	Open	0 Citizen	0 Citizen	0 538 Culey Street	662-616-9746	0	0	0	0	0 sewage problem- neighbor is going to call the health dept.	0	0	0	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	No	0				1	3B	55		
56561	9/11/2019 13:52	Open	0 Phillips	0 Phillips	0 538 Culey Street	61699746	0	0	0	0	0 plumber said the issue has nothing to do with her. Louis Thomas told her it's a city issue- it's a city issue- DFS	0	0	0	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	No	0				1	3B	55		
56886	9/26/2019	Open	0 Deletha Kelly	0 Deletha Kelly	0 457 Culey	662-616-0404	0	0	0	0	0 sewage issue, top of clean out was push up by the overflow	0	0 sewer issue	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0	unknown	unknown				1	3B	55
55312	7/11/2019 10:35	Open	0 Herrie Franklin	0 Herrie Franklin	0 318 West Alexander Street	662-820-7429	0	0	0	0	0 Leak on curve of home, standing water in front of home	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	3C	55		
56542	8/28/2019	Open	0 Herman Laimore	0 Herman Laimore	0 325 Nelson Street	0	0	0	0	0	0 sewer issue	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	3C	55		
56523	8/28/2019 9:31	Closed	0 Jo Ann Brooks	0 Jo Ann Brooks	0 304 Raines Lane	820-4439	0	0	0	0	0 Sewage back up	0	0 c/o down //	9/5/2019	Nicola Adley	670 Sewer	Jeff Appleton	0	0	0	No	0				1	3C	55		
56530	9/4/2019 11:45	Closed	0 CARLOS BROTHERS	0 CARLOS BROTHERS	0 205 PERSIMMON LANE	662-394-5521	0	0	0	0	0 DRANES ARE STOPPED UP ON CITY END, S/B U	0	possible breakdown between 2 houses, no sewer line, both houses on same c/o's //	9/5/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	No	0				1	3C	55		
56513	9/9/2019	Open	0 Curtis Ray	0 Curtis Ray	0 DRMC - West Campus	662-390-3788	0	0	0	0	0 sewer issue on the west campus - DRMC	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	3d	55		
56661	9/17/2019	Open	0 DRMC	0 DRMC	0 302 Arnold	662-390-3788	0	0	0	0	0 sewer back up	0	0 sewer issue	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	3D	55		
55318	7/11/2019 13:45	Open	0 CVille Animal Shelter	0 CVille Animal Shelter	0 Hwy 82 West@ Mill Rd.	0	0	0	0	0	0 Sewer blockage, can check.	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	9A	40		
55371	7/18/2019 8:28	Closed	0 Preston Morris	0 Preston Morris	0 1229 W. Cotton Dr.	822-3595	0	0	0	0	0 Sewer blockage, rear.	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	9A	40		
55549	7/22/2019 15:08	Closed	0 resident	0 resident	0 1174 McArthur Street	0	0	0	0	0	0 replace 4" sewer service line R King	0	0	0	0	670 Sewer	Freddie Johnson	0	0	0	No	0				1	9A	40		
55739	7/30/2019 12:56	Closed	0 Street Dept.	0 Street Dept.	0 Public Works Compound	0	0	0	0	0	0 Sewer backup @ Street Dept.	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	9A	40		
55980	8/12/2019	Closed	0 Customer customer	0 Customer customer	0 1427 Lewis Street	0	0	0	0	0	0 sewer backing up - had a plumber out Sunday. Plumber said her issue is on the city side.	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	9A	40		
56015	8/13/2019 11:27	Closed	0 Laury	0 Laury	0 1212 East Cotton Drive	662-335-3656	0	0	0	0	0 its been month several months - large hole in her backyard, water table is gone done. When will work 0 begin? Please call her. Thanks	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	9A	40		
56100	8/16/2019 9:30	Closed	0 Jermaine Thornton	0 Jermaine Thornton	0 Mill Road & Lewis Street	0	0	0	0	0	0 sewer failed in street	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	9A	40		
56203	8/22/2019 7:20	Closed	0 resident n/a	0 resident n/a	0 1212 Ridge Avenue	0	0	0	0	0	0 sink hole in rear of property sewer blockage	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	No	0				1	9A	40		

FOURTEENTH QUARTERLY REPORT
 OCTOBER 28, 2019
 PARTIAL CONSENT DECREE
 U.S. DISTRICT COURT CIVIL ACTION 4:16-cv-00018

Work Order #	Work Date	Main Status	WO Asset	Requester Name	Request Type	Address	Phone Number	Email	Event Name	Location	Customer Description	Work Type	Work Description	Date Delivered	Received By	Department	Assigned To	Longitude	Latitude	Map Address	SSO	Duration (hours) if SSO	Volume (gallons) if SSO	Waters of U.S.	Cause	Group	Mini-system	Pump Station	
56212	8/22/2019 10:49	Closed	0	0 Carter	0	1427 Lewis St.	579-5000			in street	0 s/bu, c/o front; also hole developing in street, front	0	unblocked // VG // Sewer failure here, needs attention soon	8/22/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					1	9A	40	
56224	8/22/2019 14:59	Closed	0	0 resident n/a	0	1302 Daniels Street				in rear	0 sewer	0	replace 6ft. Of 4" sewer service line	8/22/2019	0	670 Sewer	Freddie Johnson	0	0	0	No					1	9A	40	
56230	8/23/2019 8:46	Closed	0	0 resident n/a	0	1212 East Cotton Drive				in rear	0 sink hole in rear of property sewer blockage	0	replace 80' ft. of 8" sewer main line	8/14/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					1	9A	40	
56242	8/23/2019 11:25	Closed	0	0 resident n/a	0	284 Ridge Avenue				rear	0 sink hole in rear of property blockage	0	replace 30ft. of 4" sewer service line and install 4" clean out	8/20/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					1	9A	40	
56255	8/26/2019 9:04	Closed	0	0 McNeal	0	1427 Lewis Street	662-579-5000			front	0 s/bu into the back yard- street has a large hole in it and 0 two other holes are forming	0	breakdown on cant service in area'	9/5/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					1	9A	40	
56258	8/28/2019	Closed	0	0 Clarissa Lucas	0	1427 Lewis Street	662-579-5000				0 sewer backing	0	P/O front // VG	9/5/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					1	9A	40	
56455	9/5/2019 15:16	Closed	0	0 McNeal	0	1427 Lewis Street	662-579-5000				0 hole in the street - sewage backing up	0	water leak been repaired	9/5/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					1	9A	40	
56546	9/10/2019 16:52	Open	0	0 McNeal	0	1427 Lewis Street	662-579-5000				0 sewage backing up in the back yard- c/o on the front	0	0	9/10/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					1	9A	40	
56617	9/15/2019	Open	0	0 n/a	0	330 w need rd.	n/a			sewer	0 sewer is backing up	0	replace 30ft. of 4" sewer service line and install 4" clean out plus R.King City side	9/12/2019	0	670 Sewer	Freddie Johnson	0	0	0	No					1	9A	40	
56762	9/20/2019	Closed	0	0 Doug Mitchell	0	1225 Ridge Ave	662-822-2249				0 sewer backup/rear	0	0 down/#VG	9/20/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					1	9A	40	
55100	7/2/2019	Open	0	0 Johnny Harris	0	1627 Northview Drive	662-332-9332				0 Resident complains of sink whole being in back yard- 0 says she has been complaining about this since 2017	0	Unblocked // VG	7/15/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	1	1A	
55583	7/12/2019 13:29	Closed	0	0 Citizen	0	2520 Ardale Drive	662-537-7648				0 s/bu	0	problem	7/12/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	1	1A	
55515	7/22/2019 8:03	Closed	0	0 Pettis	0	1066 Duncan	662-820-4844				0 s/bu, issue, feel matter on the street and curbs	0	City side down	7/24/2019	0	670 Sewer	Jeff Appleton	0	0	0	Yes	unknown	unknown			2	1	1A	
55577	7/24/2019 8:40	Closed	0	0 Citizen	0	2520 Ardale Drive	662-580-2778				0 s/bu	0	0 // VG	7/25/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	1	1	
55597	7/24/2019 13:50	Closed	0	0 brinda w/d	0	670 Barnes Landing Road					0 ask to be connected to city sewer	0	dig out 6' clean out for resident	7/24/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	1	95	
55649	7/26/2019 10:20	Closed	0	0 Kenneth mack	0	2520 Ardale Drive	662-580-2778				0 sewage stopped up- 3rd request - clean out is in the yard	0	Unblocked // VG	7/29/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	1	1	
55923	8/8/2019 14:35	Closed	0	0 Creten	0	659 Barnes Landing Road & Abble Road	662-822-8251				0 improper clean out. You left a nail of a hole in the damn road, cneas - 0 barrels	0	leak repaired	9/5/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	1	95	
56544	9/10/2019 15:29	Open	0	0 Lewis	0	272 Barnes landing	662-347-0563				0 sewer stopped up-clean out near mailbox - yellow flag	0	0	9/10/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	1	95	
56548	9/11/2019 8:23	Open	0	0 LEWEIS	0	272 BARNES LANDING	666-234-7036 x3				0 YELLOW FLAGS IN THE AREA WHY DIDN'T YOU ALL SEE IT HE IS SITTING HERE NOW- SEWERS STOPPED UPHE CANT KEEP WAITING ON YOU ALL, HE HAS MARKED THE AREA	0	0	9/11/2019	0	670 Sewer	Jeff Appleton	0	0	0	No				2	1	95		
56608	9/13/2019	Closed	0	0 HOWARD LEWIS	0	272 Barnes Landing Road	662-347-0563				0 SEWAGE IS BACKING UP AND MAIN 0 PUMP	0	Lift station problem	9/11/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	1	95	
56881	9/13/2019 10:06	Open	0	0 Howard Lewis	0	272 Barnes Landing Rd.	347-0563				0 main line and lift station problems	0	0	9/13/2019	0	670 Sewer	Jeff Appleton	0	0	0	Yes	unknown	unknown			2	1	95	
56723	9/19/2019	Open	0	0 Howard Lewis	0	272 Barnes Landing	662-347-0563				0 sewage backing up in yard, sewer pump is not working	0	0	9/19/2019	0	670 Sewer	Jeff Appleton	0	0	0	Yes	unknown	unknown			2	1	95	
55433	7/16/2019	Closed	0	0 Jasmine Johnson	0	803 South Shelby Street					0 issue with sewer pump	0	0	7/16/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	5	14	
55432	7/16/2019	Open	0	0 Jasmine Johnson	0	803 South Shelby Street	662-931-3181				0 issue with sewer pump	0	0	7/16/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	5	14	
55518	7/22/2019	Closed	0	0 customer customer	0	741 Denton Street	662-347-5586				0 sewer issue	0	0	7/22/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	5	14	
55599	7/25/2019 8:31	Closed	0	0 citizen RW	0	Broadway/ Walnut Sts.					0 Sewer blockage	0	unblocked c/o	7/24/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	5	14	
55595	7/25/2019 8:31	Closed	0	0 citizen	0	741 S. Broadway					0 Sewer backup, c/o side.	0	unblocked // VG	7/24/2019	0	670 Sewer	Jeff Appleton	0	0	0	No					2	5	14	

FOURTEENTH QUARTERLY REPORT
 OCTOBER 28, 2019
 PARTIAL CONSENT DECREE
 U.S. DISTRICT COURT CIVIL ACTION 4:16-cv-00018

Work Order #	Work Date	Main Status	WO Asset	Requester Name	Request Type	Address	Phone Number	Email	Event Name	Location	Customer Description	Work Type	Work Description	Date Delivered	Received By	Department	Assigned To	Longitude	Latitude	Map Address	SSO	Duration (hours) if SSO	Volume (gallons) if SSO	Waters of U.S.	Cause	Group	Mini-system	Pump Station
56335	8/28/2019 14:21	Closed	0 resident n/a		0/741	South Broadway Street			0 sewer	south side of house	sewer blockage	0 repaired 4" sewer service line to the main sewer line R.King	8/28/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	5	14
55101	7/2/2019 11:39	Closed	0 Bradford		0/536	Beckwith Street	662-394-9192		0		0 please blow sewage line out. sbtu	0 city side down	7/2/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	6	13
55863	7/15/2019 10:38	Closed	0 R Washington		0	Caroline & Goodrich			0		0 S/B/U	0 c/o is down //	7/15/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	7	16
56338	9/10/2019	Closed	0 Geraldine Weathers		0/814	Walball Street	662-820-3909		0 sewer issue		0 sewer issue, customer commode and sink backing up with sewage.	0 unblocked but have improper c/o // VG	9/11/2019	Bridgette Adley	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	No					2	7	16
55867	8/6/2019 13:53	Closed	0 resident golf street		0/710	Golf Street			0 sewer line in rear	in rear	0 sewer back-up	0 replace 40 ft. 6" sewer line in rear of property	8/6/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No				2	15	10	
55993	8/13/2019 8:21	Closed	0 Henry		0/319	Cannon Street	662-378-6167		0 sewer issue		0 two clean outs - in her yard - main line stopped up and straddled this is a city sewer issue. This is the 2nd complaint of a sewer issue	0 unblocked //	8/15/2019	Bridgette Winters	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	No				2	15	10	
56090	8/15/2019	Closed	0 customer customer		0/319	Cannon Street			0 sewer issue		0 City side down	0 City side down	8/22/2019	Bridgette Adley	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	No					2	15	10
56256	8/26/2019 9:15	Closed	0 Linda May		0/635	E Sharling	347-3117		0 sewer issue		0 sbtu, c/o on side near street	0 City side down	8/26/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	15	10
55072	7/1/2019 14:59	Open	0 Nam Shepard		0/1116	Margaret Blvd	378-7874		0 sewer issue		0 Sewer problems still area in rear marked w green paint, no digging has taken place yet.	0 c/o // VG	7/1/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	23	34
55143	7/3/2019 10:30	Open	0 Nam Shepard		0/1116	Margaret Blvd	378-7874		0 sewer issue		0 Sewer problems still area in rear marked w green paint, no digging has taken place yet.	0 c/o // VG	7/3/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	23	34
55884	7/29/2019	Open	0 Stanley		0/1416	Highway J South	662-334-3687		0 sewer issue		0 sewer issue - clean out is on the opposite side on the fence.	0 unblocked //	8/12/2019	Bridgette Adley	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	No					2	23	34
55971	8/22/2019 7:57	Open	0 Curtis Amos		0/1248	Margaret Blvd	334-6211		0 sewer issue		0 Sewer blockage c/o rear.	0 unblocked //	8/22/2019	Bridgette Adley	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	No					2	23	34
56424	9/3/2019	Closed	0 Mrs. Redmon Redmon		0/1104	Groome Street	662-931-0800		0 sewer issue		0 sewer backing up in the area of 1104 Groome Street	0 rich flowing in area // VG	9/5/2019	Bridgette Adley	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	No					2	23	34
56447	9/5/2019	Closed	0 Karen Manning		0/1248	Cleste Street	662-347-4892		0 sewer issue		0 sewer issue back up	0 c/o down // sewer c/o	9/6/2019	Bridgette Adley	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	No					2	23	34
56364	9/5/2019 9:51	Closed	0 Donald Powers		0/1221	Celeste St	931-5174		0 sewer issue		0 sbtu, c/o front	0 City side down	9/5/2019	Jeff Appleton	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	No					2	23	34
56885	9/26/2019	Closed	0 Shelden plumbers		0/1136	Celeste St	662-390-7387		0 sewer issue		0 Sewer backup	0 c/o // VG	9/26/2019	M. Kearney	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	No					2	23	34
55999	7/2/2019 10:57	Closed	0 Allred		0/1532	North David Circle	662-334-6092		0 sewer issue		0 come out to see if sewage backup is her or the city. She is sick her dogs are sick, her mom is 80 she has 5 disabilities of what is making her sick, she has the CCR in her hand - she had three plumbers already out there, she said it smells like sbtu	0 city side down	6/9/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No			2	24	32		
55952	8/12/2019 10:19	Closed	0 Judy Cockerin		0/1532	N David Cir	336-6092		0 sewer issue		0 sbtu, c/o front	0 problem on foundation	8/9/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	24	32
55979	8/15/2019 9:34	Closed	0 citizen		0/1532	N David Cir	336-6092		0 sewer issue		0 sbtu, c/o front	0 Customer needs to get a plumber cutoff in the back in the yard.	8/12/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	24	32
56395	8/30/2019 15:26	Open	0 Customer		0/1616	Debra Drive			0 sewer issue		0 Sewer keeps backing up in the tub and outside	0 City side down, no c/o located	7/23/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No				2	24	63	
55561	7/23/2019 12:59	Closed	0 citizen		0/2887	Champton Dr.			0 sewer issue		0 Sewer backing up, c/o?	0 repaired 12" sewer pressure main replace 10' of pipe	7/23/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	26	45
55745	7/30/2019 16:11	Closed	0 James Bell		0/2900	Treatment Plant Rd	662-332-4951		0 sewer issue		0 big hole in his field due to sewer line leaking - 3 years - pipe is exposed and leaking - he will contact EPA & DEQ - hes tired of this because it's not your property 822-2311 cell phone	0 dig out may be needed	8/5/2019	Bridgette Winters	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	Yes	unknown	No	unknown	2	26	106	
56626	9/16/2019	Open	0 Thomas Lee		0/1148	Highland Plantation	662-378-1698		0 sewer issue		0 Water in field	0 Water in field	9/16/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	26	106
56299	8/27/2019 12:15	Closed	0 Ronnie Washington		0/1148	Highland Plantation	662-227044		0 sewer issue		0 Water in field	0 Foreman leak	8/27/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	26	106
56395	8/30/2019 15:26	Open	0 Customer		0/1616	Debra Drive			0 sewer issue		0 Sewer keeps backing up in the tub and outside	0 City side down, no c/o located	7/23/2019		Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	No					2	24	63
55548	7/12/2019	Open	0 customer customer		0/1060	Duncan Drive			0 sewer issue		0 sewage running and settled at the edge of customer yard.	0 Contractor failed to turn pump back on after work completed	7/12/2019	Bridgette Adley	670 Sewer	Jeff Appleton	Jeff Appleton	0	0	0	Yes	unknown	unknown	No	unknown	2	1A	1

FOURTEENTH QUARTERLY REPORT
 OCTOBER 28, 2019
 PARTIAL CONSENT DECREE
 U.S. DISTRICT COURT CIVIL ACTION 4:16-cv-00018

Work Order #	Work Date	Main Status	WO Asset	Requester Name	Request Type	Address	Phone Number	Email	Event Name	Location	Customer Description	Work Type	Work Description	Date Delivered	Received By	Department	Assigned To	Longitude	Latitude	Map Address	SSO	Duration (hours) if SSO	Volume (gallons) if SSO	Waters of U.S.	Cause	Group	Mini-system	Pump Station			
55586	7/24/2019 10:56	Open	0		0	1252 East John St					0 Leak in front of her water meter	0	0	0	Kyla Washington	670 Sewer		0	0	0	0	No			2	21A	29				
55783	8/2/2019 9:08	Closed	0	Terica Corbin	0	1315 Causey Drive	580-6155				0 Sewer backup, c/o?	0	0	8/1/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			2	21B	29				
56154	8/20/2019 11:25	Closed	0	Xaw Summerville	0	1506 Causey Drive	695-0000				Large hole across from this address looking toward rear area of church, hole 15 feet or so from curb, close to 0 sign	0	0	9/4/2019	Freddie Johnson	670 Sewer	Jeff Appleton	0	0	0	0	No			2	21B	29				
56011	8/15/2019 9:27	Closed	0	Jimmie Mayweather	0	1321 S.S. Mary Cir.	347-1737				0 s/bu // c/o rear	0	0	8/13/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			2	22A	34				
55357	7/15/2019 8:04	Closed	0	Specialized Auto Glass	0	2348 Paradise Lane	662-820-9589				0 s/bu - everytime it rains	0	0	7/18/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			2	28A	53				
55647	7/26/2019	Closed	0	L.G. Lavers	0	225 White Oak					0 sewer backup, cmt use toilet.	0	0	7/29/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			2	28A	53				
55710	7/29/2019 15:01	Closed	0	Chandler	0	569 Sweet Gum Cove	662-379-6544				0 SEWAGE COMING OUT OF MANHOLE	0	0	8/1/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	unknown	2	28A	53				
55947	8/9/2019	Open	0	customer customer	0	2235 Robinson Lane	662-678-7519				0 sewer backing up in street / ditch	0	0	8/9/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			2	28A	96				
55953	8/12/2019 10:17	Closed	0	washington	0	2235 Robinson Ln					0 Sewer backup, c/o front, top off	0	0	8/9/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			2	28A	96				
56082	8/15/2019	Closed	0	Shirley Ford	0	1103 White Oak Drive	662-334-7183				0 sewer issue - house flooding, commodes barely flushing	0	0	8/22/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	unknown	2	28A	53				
56106	8/16/2019 13:30	Open	0	Lynda Lavers	0	2225 White Oak Drive	335-7750				0 Sewage is not working	0	0	8/16/2019	Felicia	670 Sewer	Jeff Appleton	0	0	0	0	No			2	28A	53				
56114	8/19/2019	Open	0	L. G. Lavers	0	2225 White Oak Drive					0 sewage backing up, this complain was lodged on Friday, issue is still at hand.	0	0	8/19/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			2	28A	53				
56449	9/5/2019	Closed	0	L.G. LAVERS	0	2225 White Oak Drive					0 sewage issue - toilets will not flush	0	0	9/6/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			2	28A	53				
56774	9/23/2019 7:51	Closed	0	MOTEN	0	2244 OAK RIDGE	5402141569				0 S/B/U entire weekend	0	0	1/1/1900	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			2	28A	53				
56817	9/23/2019 13:44	Open	0	Verenna Gordon	0	2244 Oak Ridge Dr.					0 possible breakdown/sewer	0	0	1/1/1900	M. Kearney	670 Sewer	Jeff Appleton	0	0	0	0	No			2	28A	53				
56817	7/25/2019 10:13	Closed	0	citizen	0	3538 Forest Dr.					0 Sewer standing in front yard, c/o?	0	0	7/25/2019	Kyla Washington	670 Sewer	Jeff Appleton	0	0	0	0	No			2	29C	25				
55665	7/26/2019 14:56	Open	0	Angela Hood	0	429 East Clay Street	662-820-4731				0 water at stand still in front of business would like for it to be fixed	0	0	7/26/2019	Kyla Washington	670 Sewer	Jeff Appleton	0	0	0	0	No			3	6	13				
55106	7/2/2019 12:28	Open	0	Larry Tisby	0	233 Saint Anthony Street					0 Complaints of standing water on curb	0	0	7/2/2019	Kyla Washington	670 Sewer	Jeff Appleton	0	0	0	0	No			3	10	28				
55405	7/16/2019 8:56	Open	0	Charise Johnson	0	1637 Pete Street	318-828-0152				0 Citizens are unable to shower and use rest room due to sewer being backed up	0	0	7/16/2019	Kyla Washington	670 Sewer	Jeff Appleton	0	0	0	0	No			3	11	37				
56159	8/20/2019	Closed	0	customer customer	0	453 Fava Street	662-820-8598		sewer smell raw sewage		Customer is complaining of the smell of raw sewage running into a storm drain and settling into a ditch behind his property. Please contact this customer regarding this issue @ 820-8598, he also said Brad James is familiar with this issue.	0	0	9/5/2019	Bridgette Winters	670 Sewer	Ronnie Washington					0	0	0	0	Yes	unknown	unknown	3	11	37
56283	8/26/2019	Closed	0	Marie Weeks	0	461 Fava Street	662-820-6778		sewer overflow		0 sewage backing up in overflowing on customer yard. She called a plumber who informed her that it is a city sewer issue	0	0	9/5/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			3	11	37				
56287	8/26/2019 16:45	Closed	0	Wasson	0	453 Fava Street	662-820-8598		sewer issue		0 sewer running in storm drain, he doesn't know where its coming from- its dumping in the ditch on Bowman	0	0	9/5/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	unknown	3	11	37				
56264	9/3/2019	Closed	0	Doug Watson	0	Pete Street & Rose Street			sewer issue		0 Sewage running into storm drain causing a horrible 0 smell in the area.	0	0	9/5/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	unknown	3	11	37				
55615	7/25/2019 9:58	Closed	0	Meeks	0	336 Hot Collier Street	662-332-8651				0 s/bu - sewage is coming outside in the front yard-plumber has been there already- Louis Thomas been working on it- she's never had this problem before- the last rain may have caused this issue, it left a lot of debris and that's when the sewage issue s	0	0	7/29/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			3	14	10				
55655	7/26/2019	Closed	0	Ruby Meeks	0	336 Hot Collier Street	662-820-9526		sewer issue		0 sewer issue, if this is not a city issue please inform the customer, she is 0 years old.	0	0	7/29/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			3	14	10				
56894	9/9/2019	Closed	0	Albert Tyler	0	405 East Walker Street	662-537-6245		sewer back		0 sewer issue - backing up on the city side	0	0	9/11/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			3	14	10				
56669	9/17/2019	Open	0	Charles Lesau	0	547 East O'Hea Street	662-820-9595				0 Blockage on Sewer	0	0	9/17/2019	Kyla Rice	670 Sewer	Jeff Appleton	0	0	0	0	No			3	14	10				
56437	9/4/2019 14:39	Open	0	Betsy Smith	0	203 Mayfield Street	662-931-0047				0 s/bu	0	0	9/4/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			3	15	10				
55559	7/15/2019 9:18	Closed	0	Joe Valvoline Express	0	847 MLK S.	378-6777				0 Problem is on P/O side, manhole is down.	0	0	7/15/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No			3	16	54				

FOURTEENTH QUARTERLY REPORT
 OCTOBER 28, 2019
 PARTIAL CONSENT DECREE
 U.S. DISTRICT COURT CIVIL ACTION 4:16-cv-00018

Work Order #	Work Date	Main Status	WO Asset	Requester Name	Request Type	Address	Phone Number	Email	Event Name	Location	Customer Description	Work Type	Work Description	Date Delivered	Received By	Department	Assigned To	Longitude	Latitude	Map Address	SSO	Duration (hours) if SSO	Volume (gallons) if SSO	Waters of U.S.	Cause	Group	Mini-system	Pump Station
55489	7/18/2019	Closed	0	customer customer	0	847 Highway J South	0	0	sewer issue	0	Sewer line stopped up water running back into the building.	0	problem corrected //	7/24/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	3	16	54
55448	7/17/2019	11:40 Closed	0	Gloria Williams	0	561 Elizabeth St.	613-4843	0	0	0	Water leak, across from this address.	0	repaired // WE	7/17/2019	Jeff Appleton	0	670 Sewer	Jeff Appleton	0	0	0	No	0	0	0	3	17	9
55775	8/1/2019	10:15 Closed	0	James Jenkins	0	525 Pleasant Street San Ambrogio Street & Railroad Avenue	336-6925	0	0	0	S/B/L c/o ?	0	Line unblocked // VG	8/1/2019	Jeff Appleton	0	670 Sewer	Jeff Appleton	0	0	0	No	0	0	0	3	17	9
55975	8/12/2019	10:31 Open	0	Tyron	0	Railroad Avenue	662-492-28	0	0	0	hole in the street for 4-5 months from a cave in	0	Bridget Winters	0	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	17	9	
56213	8/22/2019	10:49 Open	0	Roger Mays	0	529 Termini St.	822-1770	0	0	0	skbu, c/o near street	0	system up from rain // VG	8/22/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	17	9
56293	8/27/2019	9:26 Closed	0	Chris with Invision Contractors	0	Termini & Steeby	601-880-4590	0	0	0	turn the pumps on they are doing an inspection.	0	replace 8ft of 8" sewer main line R.King	9/9/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	17	9
56299	9/10/2019	8:23 Closed	0	Resident N/A	0	527 Sun Ambrogio Street	0	0	0	0	sink hole in middle of street	0	plumber said sewer issue is on the city	0	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	17	9	
56671	9/18/2019	Open	0	Charles Douglas	0	1437 Old Leland Road	662-820-2661	0	0	0	skbu	0	Problem resolved // VG	7/16/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	17	9
55404	7/16/2019	7:20 Closed	0	Cheryl Parker	0	1270 Wortham Dr.	695-5567	0	0	0	skbu	0	Lift station problem, now resolved // VG	7/29/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	25	11
55709	7/29/2019	14:43 Closed	0	Joyce Green	0	1235 Fairview Avenue	822-7529	0	0	0	Sewer blockage, c/o side near street	0	Private property // VG	7/29/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	25	11
55740	7/30/2019	Closed	0	Ebony	0	1746 Highway J South	0	0	0	0	Chinese restaurant is having sewer issues	0	2 clean outs up from the one from the house is fine the other not making it to the street plumber said to call the city	8/12/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	25	11
56263	8/26/2019	9:55 Open	0	John Anderson	0	1212 Fairview Avenue	931-1683	0	0	0	sewer backing up plumber said its a city issue - yard	0	sewer backing up with sewage	0	670 Sewer	Felicia Winters	Jeff Appleton	0	0	0	0	No	0	0	0	3	25	11
56611	9/13/2019	Closed	0	John Anderson	0	1212 Fairview	6629316183	0	0	0	Filling up with sewage	0	unblocked // VG	8/15/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	25	11
55986	8/12/2019	15:07 Closed	0	Citizen	0	116 South Theobald Street	662-822-5223	0	0	0	skbu, line needs blow out	0	was unable to get city side down due to a blockage in the line city side	7/22/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	3	12B	35
55077	7/2/2019	8:58 Closed	0	Robert Johnson	0	1793 E. Azalea St.	822-5221	0	0	0	Sewer backup, c/o rear.	0	Pro sat city came out yesterday and serviced line but didn't do any good. Ken said to call back if sat having problems. Sat's stopped up c/o bk ken called left message 0930	0	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	12B	35	
55136	7/3/2019	9:33 Open	0	Lisa Johnson	0	1793 E. Azalea	394-5622	0	0	0	sewer breakdown, rear	0	line repaired// R.King	7/15/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	12B	35
55365	7/15/2019	10:31 Closed	0	R.Washington	0	1793 E. Azalea Dr.	0	0	0	0	sewer backup, c/o front	0	City side down	7/31/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	19A	28
55764	7/31/2019	13:31 Closed	0	Ossie Wells	0	825 Hart Dr	822-3723	0	0	0	customer states sewer issue is backing up on the city side. Reported by Jessie Whitley	0	2 improper c/o's, possible breakdown/ City side clear	9/5/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	19A	28
56292	8/23/2019	Closed	0	Sandra Reed	0	1336 Martha Drive	0	0	0	0	SEWER ISSUE	0	Main down, no c/o, problem on PRO // VG	8/2/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	22A	34
55776	8/1/2019	10:15 Open	0	Shira Hill	0	1284 South Colorado Street	537-8077	0	0	0	skbu, c/o front m/h front	0	m/h was suctioned out // VG	7/18/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	22A	34
56332	9/10/2019	11:37 Closed	0	Robert Little Kichley Care	0	2001 south medical park	8367255	0	0	0	sewage coming out man hole or drain in the parking lot	0	sewage issue	7/11/2019	Ronnie Washington	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	22B	30
55317	7/11/2019	13:40 Open	0	Citizen	0	1207 Park Lane Dr.	0	0	0	0	Sewer blockage, c/o front.	0	City side down	9/5/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	22B	30
56427	9/3/2019	Closed	0	customer Customer	0	1212 Longview Drive	662-820-7697	0	0	0	sewer issue	0	sewer issue	0	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	22B	30
55441	7/17/2019	Open	0	customer customer	0	Paradise Lane	0	0	0	0	sewage back up	0	sewage issue	0	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	28A	53
55439	7/17/2019	Closed	0	CUSTOMER	0	paradise lane	0	0	0	0	sewage issue	0	lift station trip out // VG	7/25/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	28A	53
55437	7/17/2019	9:06 Closed	0	ROGER MASSIY	0	2348 PARADISE LANE	662-378-5355	0	0	0	CANNOT FLUSH TOILETS	0	Complains of pumps not working correctly; states that every time it rains raw sewage leaks out around his home and sits for at least two days	7/25/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No	0	0	0	3	28A	53
55068	7/1/2019	11:28 Open	0	Paul Henry	0	2782 Oxford Place	662-378-6526	0	0	0	0	0	0	0	0	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	3	28B	46

FOURTEENTH QUARTERLY REPORT
 OCTOBER 28, 2019
 PARTIAL CONSENT DECREE
 U.S. DISTRICT COURT CIVIL ACTION 4:16-cv-00038

Work Order #	Work Date	Main Status	WO Asset	Requester Name	Request Type	Address	Phone Number	Email	Event Name	Location	Customer Description	Work Type	Work Description	Date Delivered	Received By	Department	Assigned To	Longitude	Latitude	Map Address	SSO	Duration (hours) if SSO	Volume (gallons) if SSO	Waters of U.S.	Cause	Group	Mini-system	Pump Station	
55409	7/16/2019	Closed	0	customer customer	0	1152 Oxford Place	662-829-4622		sewage issue		customer said sewage is coming up in the street and running into the drain.	0	Lift station tripped out // 0	7/16/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	3	28B	46	
55889	8/7/2019	9:43 Closed	0	Lucas	0	2426 Blanton Loop	662-829-9842				sewage stopped - sewage is running into street- plumber 0 is on the scene	0	City side down // VG	8/12/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No				3	28d	95	
55646	7/26/2019	Closed	0	Robert Black	0	667 Carson Street	695-7006				0 Sewer blockage, c/o side	0	Unlocked // 0	7/26/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No				3	3C	10	
56240	8/23/2019	10:46 Closed	0	Lakisha Sutton	0	913 Campbell Street	336-3529				0 s/bur, c/o front	0	got it down // 0	8/23/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No				3	3D	55	
56741	9/19/2019	Open	0	Virna Reynolds	0	233 S. Edison	662-537-4259				0 sewer problem	0	0	0	M. Kearney	670 Sewer	Jeff Appleton	0	0	0	0	No				3	3D	55	
55160	7/8/2019	8:26 Open	0	Gilmore	0	620 Reach Street	662-702-3116				0 sewer stinks badly- sewer or water line broken	0	0	0	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No				3	4A	7	
55352	7/12/2019	13:28 Closed	0	Whitley	0	311 South Harvey Street	662-820-1387				0 s/bur - 2 clean outs on the city right of way	0	both c/o's clear; could be a breakdown here	7/15/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No				3	4A	7	
55878	8/7/2019	8:04 Closed	0	Johnson	0	318 S Harvey	537-6234				0 s/bur, c/o side	0	City side down // VG	8/7/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No				3	4a	7	
56658	9/17/2019	12:55 Open	0	Lelah Brown	0	627 Valliant St.	580-2473				0 Sewer backup	0	0	1/1/1900	M. Kearney	670 Sewer	Jeff Appleton	0	0	0	0	No				3	4A	7	
56916	9/27/2019	Closed	0	Sam Wiley	0	638 Main St.	0				Sewer backing up since 10:00 a.m. today, a man came by from the city, said it was going to be fixed and it is not. The smell is awful and sewer is coming up Behind The Delta everywhere. Gentleman say he lives there and he is 90 years old is awful. Please help!	0	0	0	Freddie Johnson	670 Sewer	Freddie Johnson	33.408455	-91.0588	0	0	Yes	unknown	No	unknown	3	4B	7	
55098	7/2/2019	10:43 Closed	0	Brittany Grant	0	867 Hart Drive	62-931-0658				0 Sewage back up	0	none customer hired plumber	7/2/2019	Felicia Wilkerson	670 Sewer	Jeff Appleton	0	0	0	0	No				3	9A	28	
55591	7/24/2019	Closed	0	customer customer	0	1419 Sandy Avenue	0		sewer stopped		0 customer complaining of the sewer being stopped up- asking for immediate attention.	0	unblocked c/o // VG/DM	7/25/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No				3	9B	40	
55876	8/6/2019	Closed	0	customer customer	0	Sandy Avenue & East Reed Road	0		sewer issue		0 sewer issue with sewage overflowing into the street	0	Water leak not water leak here	8/12/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No				3	9B	40	
55838	8/6/2019	8:44 Closed	0	Bill Broznovich	0	1414 Sandy St	0				0 Sewer running out into street, front, can check.	0	0	8/6/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No				3	9b	40	
55929	8/8/2019	13:05 Closed	0	Paul Bransley (property owner)	0	1414 Sandy Avenue	0				0 sewage discharges from c/o issue around c/o but report 0 fresh, determined leak from meter (no disputes finding).	0	0	8/8/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	3	9b	40	
55945	8/9/2019	9:27 Closed	0	Brantly	0	1414 Sandy Avenue	662-820-4224				0 sewage running down the street- 2 weeks	0	0	8/12/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	3	9B	40	
55879	8/12/2019	10:02 Closed	0	Paul Brantly	0	Sandy Avenue	0				0 Sewer running down street, no address, front	0	0	8/27/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No				3	9B	40	
56098	8/16/2019	9:15 Closed	0	Eddie Iozzinski	0	615 East Reed Road	0		0 sink hole	edge of street	0 sewer issue	0	replace 8' of 4" sewer service line R King	8/23/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No				3	9B	40	
56531	9/4/2019	Closed	0	Sykes Kirby	0	664 Tampa Drive	662-347-8100				0 sewer issue	0	system drained // 0	9/5/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No				3	9B	40	
56555	9/11/2019	9:57 Open	0	Moerwe	0	1415 Iby Street	8203019				0 s/bur- something was lodged in the toilet, plumber got it out	0	0	0	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No				3	9B	40	
56895	9/26/2019	15:35 Closed	0	Stewart	0	147 High	6627023344				0 sewage backing up- cant wash clothes- low water pressure- backing up	0	0	1/1/1900	Bridgette Winters	670 Sewer	Bridgette Winters	33.382985	-91.0553	0	0	No				3	9C	40	
56401	9/3/2019	Closed	0	customer customer	0	1414 Sandy Avenue	0		sewer issue		0 reporting sewage running down street	0	0	9/5/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	Yes	unknown	No	unknown	3		40	
55699	7/29/2019	11:47 Closed	0	Ebony Brown	0	1746 MLK S.	378-8898				0 Sewer backup, c/o front Restaurant	0	0	7/29/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No				PRIVATE	PRIVATE	PRIVATE	PRIVATE
55742	7/30/2019	14:30 Closed	0	Hitchia restaurant	0	Hwy 1 south	662-931-7002		Kroger parking lot		0 s/bur- plumber said his city issue	0	0	8/12/2019	Bridgette Winters	670 Sewer	Jeff Appleton	0	0	0	0	No				PRIVATE	PRIVATE	PRIVATE	PRIVATE
55319	7/11/2019	13:44 Open	0	Citizen	0	819 Dahlirva Dr.	0				0 s/bur blockage, c/o at ROW.	0	0	7/11/2019	Rennie Washington	670 Sewer	Jeff Appleton	0	0	0	0	No				8	8	17	
55530	7/22/2019	10:56 Closed	0	Bobby Buchannon	0	1343 E. John St.	347-8137				0 Sewer blockage, c/o front.	0	0	7/22/2019	Jeff Appleton	670 Sewer	Jeff Appleton	0	0	0	0	No					21A	29	
55651	7/26/2019	Closed	0	customer customer	0	659 Pickett Street	0		sewer issue		0 sewage back-up	0	0	7/29/2019	Bridgette Adley	670 Sewer	Jeff Appleton	0	0	0	0	No					32A	21	

WASTEWATER BYPASS REPORT

TO THE MISSISSIPPI OFFICE OF POLLUTION CONTROL

- I. PERMITTEE NAME: CITY OF GREENVILLE, MISSISSIPPI
- II. PERMIT NUMBER: MS0020184
- III. BYPASS SOURCE (I.E. MANHOLE, PUMP STATION, ETC.): Force Main
- IV. SOURCE LOCATION (I.E. STREET, ETC.): 1148 Highland Plantation Road
- V. DATE/TIME BYPASS BEGAN: September 18, 2019 @ 4:00 pm
- VI. DATE/TIME BYPASS ENDED: Bypass has been contained.
- VII. VOLUME OF WASTEWATER BYPASSED (ESTIMATE IF NECESSARY) Approximately 1,500 gals
- VIII. STATE WATERS EFFECTED (I.E. RIVER, STREAM, LAKE, ETC. NONE): n/a
- IX. CAUSE OF BYPASS: unknown
- X. TEMPORARY CORRECTIVE ACTIONS TAKEN: Bypass has been contained.
- XI. PERMANENT CORRECTIVE ACTIONS: Contractor notified, will start work soon.
- XII. NUMBER OF BYPASSES AT THIS LOCATION IN THE PAST 12 MONTHS: 3
- XIII. WHAT ACTIONS WERE TAKEN TO PREVENT OR MINIMIZE ADVERSE ENVIRONMENTAL IMPACT? ___
- XIV. IF BYPASS CAUSED DUE TO INFLOW OF RAINFALL, HOW MANY INCHES OF RAIN FELL IN THE AREA? ___

SIGNATURE: Ronnie Washington
TITLE: Street Utility Director
ADDRESS: 340 MAIN STREET
GREENVILLE, MISSISSIPPI 38701
Date: 9/20/19